

## Tool Box Meeting Electrical Safety – Shop-made devices

---



Shop-made electrical devices can expose workers to shocks and electrocution. All electrical tools and cord sets should be contractor quality and be inspected by a competent person each time they are used. Tools or cord sets found to be unsafe should immediately be tagged and taken out of service. Repairs should be made by the manufacturer or a qualified person.

The shop-made cord set in the photo above is being used outdoors. Review this photo with your crew and discuss any hazards noted. In the section below, list the hazards created by this type of device and the controls that may help reduce or eliminate them.

Complete your company information at the bottom of this page and have your crew sign-in on page 2.

Additional safety rules and regulations can be found in 29 CFR 1926.

<u>Hazards noted, possible exposures</u>	<u>Suggested controls or actions</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

---

Company name

Project name

---

Supervisor name

Date

---

